

UC SERIES

IMPORTANT SAFEGUARDS

When using electrical equipment, basic safety precautions should always be followed, including the following:

THIS PRODUCT MUST BE INSTALLED IN ACCORDANCE WITH THE APPLICABLE INSTALLATION CODE BY A PERSON FAMILIAR WITH THE CONSTRUCTION AND OPERATION OF THE PRODUCT AND THE HAZARDS INVOLVED. DISCONNECT POWER TO ALL CIRCUITS BEFORE WIRING FIXTURE. INSTALL IN ACCORDANCE WITH ALL NATIONAL, STATE, AND LOCAL CODES. DO NOT CONNECT TO AN UNGROUNDED SUPPLY. READ ALL FIXTURE MARKINGS AND LABELS TO ENSURE CORRECT INSTALLATION OF FIXTURE. SUPPLEMENTAL INSTRUCTIONS MAY BE LOCATED ON THE FIXTURE, IN ADDITION TO THIS INSTRUCTION SHEET, REGARDING ORIENTATION, OR MOUNTING RESTRICTIONS. FIXTURE IS INTENDED FOR UNDERCABINET OR UNDERSHELF MOUNTING. FAILURE TO INSTALL ON A MECHANICALLY-SOUND SURFACE MAY RESULT IN PERSONAL INJURY, FIXTURE DAMAGE, OR POTENTIAL FIRE HAZARD. DO NOT INSTALL OUTDOORS OR IN APPLICATIONS NOT INTENDED FOR USE. READ INSTRUCTIONS PROVIDED WITH ANY STRATALUME CONNECTS™ ACCESSORY. THESE MAY OVERRIDE CERTAIN INSTALLATION PROCEDURES FOR LUMINAIRE INSTALLATION



INSTALLATION INSTRUCTIONS

SAVE THESE INSTRUCTIONS

This instruction sheet applies for the Stratalume UC Series UCDD, UCSD, UC DL and UC SL.

FIXTURE MOUNTING PROCEDURE

Before beginning, make sure all components have been unpacked from the shipping carton.

The Stratalume UC fixtures can be mounted individually only. Use the following steps to mount all Stratalume UC fixtures:

1. Determine where fixture(s) will be mounted.
2. Ensure adequate clearance exists at the rear (or side) of the fixture for electrical connection with FMC or NM wire.
3. For applications where electrical connection is made to a cord and plug (CP) allow an additional clearance for side cord and plug will be installed.

INDIVIDUAL-MOUNT

4. Remove lens and electrical gear tray from fixture.
5. Refer to individual specification sheet for mounting dimensions for each fixture series or use base as template to locate mounting positions.
6. Secure fixtures at opposite ends using two #8 screws. (UCDL,UCSL installation kit supplied)

Electrical Connection – Hardwired Units

MAKE SURE AC POWER IS OFF BEFORE MAKING ELECTRICAL CONNECTION TO FIXTURE(S).



CONNECTION TO FIXTURE

1. On UCSL, UC DL fixtures, attach supplied NM/FMC connector to preferred 1/2" double "D" knockout. On UCSD and UCDD models, use standard 1/2" conduit fitting.
2. Bring power into fixture and connect to ballast (use 90°C minimum conductors)
3. Install electrical gear tray and lens.
4. Turn power on.

CUSTOMER SERVICE

For technical assistance, call 1-800-4KENALL (1-800-453-6255).

WARRANTY

For warranty information visit www.kenall.com/Resources/Certified-Performance-Warranties

